

# Declaration of Conformity



For the Dutch Safety Directive **PGS 37-1**

Applicable to Battery Energy Storage Systems

Energy Storage Products:

LUNA2000-215-2S10

Statement:

The above-mentioned Energy Storage Products fulfill the minimum product safety requirements listed in the PGS 37-1. Compliance has been demonstrated with test reports for:

- IEC 62933-5-2 (Applies to energy storage product)
- IEC 62619 (Applies to battery module)
- UL9540A (Applies to the battery module and the battery rack)

The application of these products is considered to be "Typical 2" (Energy Storage Plant) and "Typical 3" (Energy Storage Plant with non-accessible modules in the open air). Placement of the products shall be in accordance with PGS requirements "M50", "M51", and "M52". It is the responsibility of the installer to observe the safety distance requirements for the energy storage plant.

Huawei Technologies (Netherlands) B.V.

Signed:

Date: 11th of December 2024



**Bouke van der Weerd**

Chief Technology Officer – West European Multi-Country Digital Power Smart PV Development